

Bruno Eder Gesellschaft m.b.H.

Tel.: +43 (1) 789 99 11 - 0 Fax: +43 (1) 789 99 11 - 25

Stättermayergasse 3, A-1150 Wien

Fire Department Key Box FSK-T

corresponding to the requirement of TRVB S 114

Application:

Additional key box with electrical unlocking and optional key monitoring. The FSK-T can be extended up to a maximum configuration in groups of four keys.

Attention: interior use only!

- Variants from 8 to 40 keys (gradation at four keys)
- Prepared for installation of HZ 32 single-profile cylinders
- Fire department lock on the outside, to open the door in case of an alarm
- Electrically locked, line-related key assemblies
- Fire department release lock inside to release all keys
- Display and key removal via LED button
- Emergency opening lock
- Cable entry from the bottom or the top

Required for operation of the FSK-T:

- Supply voltage
12 V or 24 V (2 A slow-blow fuse)
- Activation
The feed line to the FSK-T must be max. 10 meters and must be a fire detection cable 2x2x0.8
- Activation key assembly
For each assembly, 2 cores, potential-free NO contact, are required.

Dimensions

	FSK-T20	FSK-T40
Width	450mm	650mm
Height	360mm	360mm
Depth	230mm	230mm
Weight	30kg	45kg

Color: RAL 7032 powder-coated
other colors at additional charge

Type of protection: IP30

Application:

Upon using the fire department key box, annual maintenance according to ÖNORM F 3070 is specified, which is undertaken by our technicians.

