

# Fire Department

## Operation of the MSS-T in case of a fire alarm

### In case of a pending alarm:

- Insert the FD key into the FD lock and turn it to the right (up to the stop, hold)
- Open the lower big door
- Activated key: flashing LED button,  
non-activated key: LED button illuminated
- Remove the key by pressing the LED (button),  
then turn the key to the left and remove it

### Return (with the door open):

- Insert the key into the cylinder and turn it to the right

### Return (with the door closed):

- Insert the FD key into the FD lock and turn it to the right  
(up to the stop, hold)
- Open the lower big door
- Insert the key into the cylinder and turn it to the right

### Buzzer:

- End of acoustic signal following return of all keys

### Attention!

Following reset of the central fire alarm system (BMZ), no key removal is possible anymore. If required, a new fire alarm would have to be triggered.